

FURNACE Support

GOODMAN MODEL # MEC96 GAS FURNACE

User Manual is located in a folder atop your furnace.

Regular Maintenance should be performed by a qualified service technician only. It is suggested that you consider a contract for annual maintenance - several providers are on the previously distributed Vendor List.

What YOU Can/Should Do:

- 1) Change the Filter, every 1-3 months
- 2) Neutralize the Condensation Pipe
- 3) Check the Air Intake Pipe

1) Change the Filter 1"x16"x20" filters are available at Home Depot or Lowe's. Open the lid of the filter compartment by simply lifting it. Remove the old filter. Note the suggestion to put a little duct tape tab on the new filter to make it easier to lift next time.



Note that the filter has an arrow printed on the edge. That arrow should be pointed toward the furnace.



2) Neutralize the Condensation Pipe, with 1-2 Tablespoons of bleach to avoid smell from water collection in the elbow.



3) Check the Air Intake Pipe. It is the curved piece on top of your furnace, which may be dirty from original construction. Also, if you are doing anything dusty in your basement, you should turn the furnace off, and cover the opening of that pipe. There is a switch on the furnace - or use your thermostat.



NOTE: You may want to register your furnace, for future warranty protection. You can do that online at www.goodmanmfg.com/product-registration. You'll need the model and serial numbers from the sticker on the unit, and the info about the Installer, who was RWK Heating, 781-234-5120



Prepared by the Summer Reach Homeowners Maintenance and Repair Support Club.

The user recognizes that this information has been created by their neighbors on a voluntary basis and is not intended to supersede any information in their owner's manual regarding maintenance or service. The List of Providers is for advisory purposes only and in no way should be construed as warranty or guarantee. User assumes all responsibility to determine the fitness of the service provider for their particular task. Version 03.15.2021.